

COMMONWEALTH OF KENTUCKY  
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF MEADE COUNTY WATER )  
DISTRICT FOR A DEVIATION OF EMERGENCY )  
STAND-BY PUMPING EQUIPMENT REQUIRED BY ) CASE NO. 10119  
807 KAR 5:066, SECTION 5(3) )

O R D E R

By letter received December 30, 1987, Meade County Water District ("Meade Water") requested a deviation from 807 KAR 5:066, Section 5(3). Said request proposed that Meade Water be relieved from the requirement to provide standby pumping equipment for its hydropneumatic pumping stations that are operating with only one pump.

Additional information is needed for an adequate and proper consideration of the deviation requested by Meade Water.

IT IS THEREFORE ORDERED that Meade Water shall file an original and seven copies of the following information with the Commission with a copy to all parties of record no later than March 4, 1988.

1. Provide the following information for each pumping station that is operating with only one pump;
  - a. Pump station location,
  - b. Number of customers dependent on this pumping station for service pressure,

c. Time required for replacement of pump in the event of pump failure,

d. Cost of a replacement pump for this station,

e. Pump characteristics essential to the selection of a replacement pump or duplicate pump,

f. Pump station modifications needed to add a second pump, and

g. Cost of the modifications described in (e) above.

2. If Meade Water kept spares for replacement of failed pumps, how many spare pumps would be needed considering the pumping requirements of each pump station for which a spare may be needed?

If the above listed items of information cannot be provided by March 4, 1988, Meade Water should submit a motion for an extension of time stating the reason a delay is necessary and include a date by which it will be furnished. Such motion will be considered by the Commission. Meade Water shall furnish with each response the name of the witness who will be available for responding to questions concerning each item of information requested should a public hearing be required in this matter.

Done at Frankfort, Kentucky, this 1st day of February, 1988.

ATTEST:

PUBLIC SERVICE COMMISSION

\_\_\_\_\_  
Executive Director

*Richard D. Hermann, Jr.*  
\_\_\_\_\_  
For the Commission